Storm Damage Report (updated on 05.04.2023 till 09:00 P.M.) Houses Damaged Other loss																
	District	Rev. Circle	Name of Village affected	No. of Village affected	Total Population affected	Houses Damaged							Other loss			
Date of occurrence						Parti Kutcha		Fully da Kutcha		Any other	Human life lost	Crop Damage (In Hect)	(Livestock, Road Communicati on etc)	Ex-Gratia distributed	I Time	GPS Co- ordinates
04-04-2023	Nagaon	Raha	Raha R.C.:- Raha,Monipurtup,Kahargaon, Petborha,Meteka,Chaparmuk h,Dighaliati,Mulankata,Saraga on,Bagariguri,Kamgaon,Haria mukh,Dighaldori,Khaigarh,Lau phulabori,Sewguri, Sengajan	17	245	35	7	8	1	2 No Pub Sengajan LP, Pachim KV ME were partially Damage	0	0	-	-	,	-
04-04-2023	Cachar	Sonai, Lakhipur	Sonai R.C.:-Rajghat, Dholi, Bagha Lakhipur R.C:- Pollarbond	4	7	0	1	1	0	377 Rajghat L.P. School Damage	0	0	-	-		-
04-04-2023	Dhemaji	Sissiborgaon	Sissiborgaon R.C:- Nagaon Betanipam	1	0	0	0	0	0	AWS Centre partially Damage	0	0	-	-	-	-
04-04-2023	Kamrup	Kamalpur, North Guwahati	Kamalpur R.C:- Bihdia, Dakshin Shingra, Moihati, Bardekpar, Dwigunpar, Barhata, Sajei, Nasatra, Athgaon North Guwahati R.C.:- Changsari	10	0	0	0	0	0	0	0	0	-	-	-	-

05-04-2023 Karbi-Anglong	Silonijan, Diphu	SiloniJan R.C.:- I.Nambor Rev. Village (Hemlet village) Paniram Terang Langtuk Rongpi 2.Jilangso Rev. Village Diphu R.C.:-	² 34	122 374	34 69	0	1	0	0	0	0	-	-	-	-
--------------------------	---------------------	---	----------------	-------------------	-----------------	---	---	---	---	---	---	---	---	---	---

Remarks

APDCL Raha:

- 1. HT 9.75m PSC pole-1, LT 7.5m PSC pole-22, Conductor-2 km were damaged.
- 2. HT 9.75m PSC pole- 1, LT 7.5m PSC pole- 22, Conductor- 2 km were replaced
- 3. Line Length (ckt km)- 2 km were damaged.
- 4. Lene Length (ckt km)- 2 km were replaced. PHE Raha
- 1. Chaparmukh PWSS was fully damaged.
- 2. Pahupurikhaiti (SAGY) PWSS was partially damaged. Irrigation Raha Sub division Hybrid Tubwell Scheme at Pachim Kachua was Partially damaged

HT Double Pole damaged near Bagha substation in Dholai 11 KV feeder due to today's storm damage i.e.on 5/4/2023.

-

Transformer: 3 nos, Conductor: 5.015 KM, 3 nos. Pole 4 nos. Pole, LT line: 1.0 KM

I)Dhansiri Bazar Anganwadi Centre (Roof was damaged) 2)New Kothal Guri Anganwadi Centre (Roof was damaged)

-