

Relief Distributed	District	Rice (in Q)	Dal (in Q)	Salt (in Q)	M. Oil (in L)	Cattle Feed - Green Fooder (in Q)	Cattle Feed - Wheat Bran (in Q)	Cattle Feed - Rice Bran (in Q)				
	Baksa	0	0	0	0	0	0	0	0			
	Dhubri	0	0	0	0	0	0	0	0			
	Nalbari	0	0	0	0	0	0	0	0			
	South Salmara	0	0	0	0	0	0	0	0			
	Kokrajhar	0	0	0	0	0	0	0	0			
	Total	0	0	0	0	0	0	0	0			
Relief Distributed - Others	District	Baby Food Liquid		Baby Food Solid		Others						
	Baksa											
	Dhubri											
	Nalbari											
	South Salmara											
	Kokrajhar											
Infrastructure Damaged - Others	District	Revenue Circle	Damages	Number	Name	Department	Village	Location		Longitude	Latitude	Remarks
	Baksa	Barama	Power Dept. Transformers (in Nos)	2	Kharuajan 25 kva transformer	APDCL	Kharuajan	Kharuajan		91.37	26.56	1 nos transformer has been damaged
					Murkuchiapara 25 kva transformer	APDCL	Murkuchiapara	Murkuchiapara		91.41	26.57	1 nos transformer has been damaged
			Power Dept. Conductors (in Nos)	1	Barama	APDCL	Barama	Barama		91.37	26.53	700 meter conductors have been damaged
			Power Dept. Poles (in Nos)	1	Barama	APDCL	Barama	Barama		91.37	26.53	1 nos LT pole have been damaged
	Jalah	Power Dept. Poles (in Nos)	3	Pathsala ESD	APDCL	Pub khagrabari	Phuloguri, Charna, Simla		91.18	26.71	As per information received from Pathsala ESD 3nos Poles broken on 20-06-2024.	
			1	Pathsala ESD	APDCL	Pub khagrabari	Phularguri, Charna		91.18	26.71	As per information received from Pathsala ESD 2000 mtr conductors damage on 20-06-2024	
	Baska	Power Dept. Conductors (in Nos)	1	APDCL Barama	APDCL	Sripurdeor	Sripurdeor river		91.34	26.61	400 metres HT conductor damage at village Sripurdeor due to storm as reported SDE APDCL, Barama	
			1	APDCL Barama	APDCL	Sripurdeor	Near Sripurdeor river.		91.34	26.61	1 no. of HT electric pole damage at village	

										Sripurdeor due to storm as reported by SDE, APDCL, Barama
Dhubri	Dhubri	Power Dept. Poles (in Nos)	2	Poles (in Nos)	APDCL	AdabariPt.I	Adabari			8.5 mtr, PSC POLE (in no)
				Poles (in Nos)	APDCL	AdabariPt.II	Adabari			8.5 mtr, PSC POLE (in no)
		Power Dept. Transformers (in Nos)	1	Transformers	APDCL	Borbila Pt.II	Borbila			Transformers affected 25 KVA
		Power Dept. Conductors (in Nos)	1	Damaged Conductor (in km)	APDCL	AdabariPt.II	Adabari			L.T- 1.5 KM
Chapar	Power Dept. Conductors (in Nos)	2	POWER DEPT CONDUCTORS	APDCL	Kajipara Pt- III	KAJIPARA PT-I, KAJIPARA PT-II, KAJIPARA PT-III, SALKOCHA, CHANDARDINGA PAHAR, KURSHAGATI, ROWMARA T-I, SREGRAM PT-IV, AREARJHAR PT-I, TARANGAPUR PT-I, HATIPOT PT-I	90.46	26.27	RACCOON- 5 KMS RABBIT- 4 KMS	
Golakganj	Power Dept. Transformers (in Nos)	5	Power Dept. Transformers in Nos.	APDCL	Ramnath Para	Garopara	89.86	26.28	63 KVA Power Dept. Transformer damage- 1 No.	
					Kamandanga Kuti	Bagdogra	89.92	26.3	25 KVA Power Dept. Transformer damage- 1 No.	
					Ramnath Para	Ghritingarkhuti Raipara	89.83	26.33	25 KVA Power Dept. Transformer damage- 1 No.	
					Bherbheri	Raipara	89.87	26.32	25 KVA Power Dept. Transformer damage- 1 No.	
					Uzan Petla Pt-2	Patanerkuti	89.87	26.28	25 KVA Power Dept. Transformer damage- 1 No.	
Agamoni	Power Dept. Transformers (in Nos)	2	Transformer	APDCL	Jhapushabari Pt 2	Jhapusabari Pt-2	89.74	26.27	Transformer 25 KVA - 2 NOS	
	Power Dept. Conductors (in Nos)	2	Conductor(KM)	APDCL	Bishkhowa Pt 1	Bishkhowa Pt-1 Bishkhowa Pt-2 Bishkhowa Pt-3	89.74	26.23	LT-6.5 KM HT-3.5 KM	
Nalbari	Barbhag	Power Dept. Conductors (in Nos)	1	Conductor	APDCL	Barsimaliya	barsimaliya			1.1 k.m,

		Power Dept. Transformers (in Nos)	1	Transformer	APDCL	Barsimaliya	barsimaliya			1 no.
	Nalbari	Power Dept. Transformers (in Nos)	1	transformer	APDCL	Janigog	janigog			1 no transformer damaged
		Power Dept. Conductors (in Nos)	1	conductor	APDCL	Janigog	janigog			As per the report of APDCL, 1.4 km conductor damaged
South Salmara	South Salmara	Power Dept. Transformers (in Nos)	1	Transformer	APDCL	Khopati Pt-IV	Khopati pt-iv	89.92	25.77	1 no. of transformer damage due to lightning on 19-06-2024.
Kokrajhar	Bagribari	Power Dept. Transformers (in Nos)	2	TRANSFORMER	APDCL	Jaldoba Pt-I	JOLDOBA PT I	89.87	26.23	
				TRANSFORMER	APDCL	Pastibari(Kazigaon Mouza)	PASTIBARI	89.88	26.28	
Remarks	District	Details								
	Baksa									
	Dhubri									
	Nalbari									
	South Salmara	(South Salmara - as per report received from SDE APDCL, Mankachar on 20-06-2024.)								
	Kokrajhar									
Report Generated On: 20-06-2024 06:10 PM										