

Assam Storm Report as on 29-06-2024									
Assam Storm Report as on 29-06-2024									
Particulars									
District Affected	No. of Districts Affected	Name of Affected Districts							
	4	Sivasagar, Dibrugarh, Nalbari, Lakhimpur							
No. Of Revenue Circles Affected	4								
Name Of Revenue Circle Affected	District	Total	Revenue Circle						
	Sivasagar	1	Amguri						
	Dibrugarh	1	Moran						
	Nalbari	1	Nalbari						
	Lakhimpur	1	Nowboicha						
	Total	4							
Villages Affected	District	Total	Revenue Circle						
	Sivasagar	1	(Amguri 1)						
	Dibrugarh	5	(Moran 5)						
	Nalbari	2	(Nalbari 2)						
	Lakhimpur	6	(Nowboicha 6)						
Total	14								
Population Affected	District	Male	Female	Children	Total Population	Population Details			
	Sivasagar	2	3	1	6	(Amguri 6)			
	Dibrugarh	0	0	0	0	(Moran 0)			
	Nalbari	0	0	0	0	(Nalbari 0)			
	Lakhimpur	0	0	0	0	(Nowboicha 0)			
Total	2	3	1	6					
Relief Camps / Centres Opened	District	Total	Relief Camp			Relief Distribution Centres			
	Sivasagar	0	0 (Amguri 0)			0 (Amguri 0)			
	Dibrugarh	0	0 (Moran 0)			0 (Moran 0)			
	Nalbari	0	0 (Nalbari 0)			0 (Nalbari 0)			
	Lakhimpur	0	0 (Nowboicha 0)			0 (Nowboicha 0)			
Total	0	0			0				
Inmates In Relief Camps	District	Total	Revenue Circlewise		Male	Female	Children	Pregnant / Lactating Mother	Person with Disability
	Sivasagar	0	(Amguri 0)		0	0	0	0	0
	Dibrugarh	0	(Moran 0)		0	0	0	0	0
	Nalbari	0	(Nalbari 0)		0	0	0	0	0
	Lakhimpur	0	(Nowboicha 0)		0	0	0	0	0
Total	0			0	0	0	0	0	
Human Lives Lost - Confirmed	District	Total	Male	Female	Children		Others	Revenue Circlewise	
					Male	Female			
	Sivasagar	0	0	0	0	0	0	0 (Amguri 0)	
	Dibrugarh	0	0	0	0	0	0	0 (Moran 0)	
	Nalbari	0	0	0	0	0	0	0 (Nalbari 0)	
	Lakhimpur	0	0	0	0	0	0	0 (Nowboicha 0)	
Total	0	0	0	0	0	0			
Human Lives Lost - Missing	District	Total	Male	Female	Children		Others	Revenue Circlewise	
					Male	Female			
	Sivasagar	0	0	0	0	0	0	0 (Amguri 0)	
	Dibrugarh	0	0	0	0	0	0	0 (Moran 0)	
	Nalbari	0	0	0	0	0	0	0 (Nalbari 0)	
	Lakhimpur	0	0	0	0	0	0	0 (Nowboicha 0)	
Total	0	0	0	0	0	0			
Human Lives Lost - Injured	District	Total	Male	Female	Children		Others	Revenue Circlewise	
					Male	Female			
	Sivasagar	0	0	0	0	0	0	0 (Amguri 0)	
	Dibrugarh	0	0	0	0	0	0	0 (Moran 0)	

		Power Dept. Conductors (in Nos)	6	Conductor	APDCL	Monipather Gaon	Khowang Monipother			1 No. Of ACSR Raccoon 0.2 Km damaged
				Conductor	APDCL	11/164 O.R.R. Grant	Khowang Azarguri and Khowang Chariali			1 No of ACSR Raccoon 0.6 Km damaged at Khowang Azarguri and 1 No of ACSR Raccoon 0.5 Km damaged at Khowang Chariali
				Conductor	APDCL	Padumoni No-gaon	Khowang Padumoni			1 No of ACSR Raccoon 0.6 Km damaged
				Conductor	APDCL	No. 1 Deoghoria Gaon	Deogharia			1 No of ACSR Raccoon 0.4 km damaged
				Conductor	APDCL	Sensuwapukhuri Gaon	Senchowapukhuri			1 No. of ACSR Raccoon 0.5 Km damaged
		Power Dept. Transformers (in Nos)	1	Transformer	APDCL	Padumoni No-gaon	Khowang Padumoni			1 No of distribution transformer-63 KVA damaged
Nalbari	Nalbari	Power Dept. Conductors (in Nos)	2	Conductor	APDCL	Pu Kalakuchi	Pub Kalakuchi			As per the report of APDCL, 0.8 km conductor damaged
				Conductor	APDCL	Chandkuchi	Chandkuchi			As per the report of APDCL, 1.6 km conductor damaged
Lakhimpur	Nowboicha	Power Dept. Poles (in Nos)	3	PSC Poles	APDCL	Chumoni	3 Nos. of loactions	94.01	27.2	PSC pole 8.5 Mtrs- 3 Nos.
		Power Dept. Conductors (in Nos)	6	Electrical Conductors	APDCL	Konwarpur	Konwarpur	94.01	27.14	Conductors-0.70 KM
				Electrical Conductors	APDCL	Hariyah Bari	Hariyah Bari			Conductors-0.75 KM
				Electrical Conductors	APDCL	Pandhowa	Pachim Pandhowa	94.02	27.09	Conductors-0.85 KM
				Electrical Conductors	APDCL	Chumoni	Kuhiar Bari, Chumoni	94.01	27.2	Conductors-2.40 KM
				Electrical Conductors	APDCL	No. 2 Kowadonga	No.2 Kowadonga	94.02	27.18	Conductors-0.90 KM
				Electrical Conductors	APDCL	Saru Doloni	Sarudoloni	94.04	27.16	Conductors-0.95 KM
Remarks	District	Details								
	Sivasagar									
	Dibrugarh									
	Nalbari									
	Lakhimpur	(Nowboicha - As per report received from APDCL, Nowboicha ESD, on dated. 29.06.2024, 3 Nos. of PSC Poles (8.5 Mtrs) and 6.55 KM conudctors were damaged due to heavy rain and storm. This report is prepared based on preliminary survey only. The quantity of materials may vary as per actual field requirement.)								
Report Generated On: 29-06-2024 08:34 PM										